



Product Service

CERTIFICATE

No. Z2 090500

Holder of Certificate: **GCLE-EXE Energy Industry CO.LTD**
501-2 Manufacturing Park 65 Dacang Road
Zhonglou –Jiangsu Province

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module
Poly-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 882162000481

Valid until: 2024-11-25

(Xinlian LUO)

Production System IBuild 20200122.11



Product Service

CERTIFICATE

No. Z2 090500

Model(s): 1000V DC Module
A-Mxxx/72-B(xxx=330-405), (xxx=330-405, in step of 5)
A-Mxxx/60-B(xxx=280-345), (xxx=280-345, in step of 5)
A-HCMxxx/144-B(xxx=380-415), (xxx=380-415, in step of 5)
A-HCMxxx/120-B(xxx=320-360), (xxx=320-360, in step of 5)
A-Pxxx/72(xxx=310-345), (xxx=310-345, in step of 5)
A-Pxxx/60(xxx=275-300), (xxx=275-300, in step of 5)
1500V DC Module
A-Mxxx/72-B (xxx=330-405), (xxx=330-405, in step of 5)
A-Mxxx/60-B (xxx=280-345), (xxx=280-345, in step of 5)
A-HCMxxx/144-B (xxx=380-415), (xxx=380-415, in step of 5)
A-HCMxxx/120-B (xxx=320-360), (xxx=320-360, in step of 5)
xxx is standing for rated output power at STC

Parameters:

Construction: Framed, with Junction box, Cable and Connectors.

Safety Class: Class II

Maximum System Voltage: 1500V DC or 1000V DC

Fire Safety Class: Class C according to UL790

Tested according to:

IEC 61215-1(ed.1)
IEC 61215-1-1(ed.1)
IEC 61215-2(ed.1)
IEC 61730-1(ed.2)
IEC 61730-2(ed.2)
EN 61215-1:2016
EN 61215-1-1:2016
EN 61215-2:2017
EN IEC 61730-1:2018
EN IEC 61730-2:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018/AC:2018-06

Production Facility(ies):

002614

Production System / Build 2020M27 11